

**Comprehensive Safety Inspection
State Requirements for Educational Facilities**

Initial Inspection: Dec 14, 2009

Safety Department
4200A N.W. 10th Avenue
Oakland Park, FL 33309
(754) 321-4200

Fiscal Year: 2009-2010
Broward County School District - Charter Schools
Somerset Academy East Preparatory Loc. No: 5391
2000 South State Road 7
Miramar, FL 33027
(954) 987-7890

Miramar Fire Rescue
14801 SW 27th Street
Miramar, FL 33025
(954) 602-4602

Victoria Stanford #112821
Municipal Firesafety Inspector

Fire Safety Casualty Sanitation

* Bill Keys #81910
Municipal Firesafety Inspector
(Fire Violations only)

69A-58 No. Sub Para.	Pri	Location		Type Def. M-O-C	Est. Cost	Deficiency Description and Corrective Action Required	# of Times Cited	Scheduled for Correction Not Later Than	Current Year Status	Work Order #
		Bldg No.	Room No.							
* 16 f2 02	B	C	CAFE			install light covers <i>Small yellow light-South</i>				
* 11 a3 2	C	C	CAFE			post mechanical room sign <i>Near South Exit</i>				
* 15 a5 a1	B	C	CAFE			post no combustibile storage sign <i>Mechanical Rm Door South Side</i>				
* 10 h 3	D	C	CLOSET			install smoke detector <i>Cafeteria South table Closet</i>				
* 10 h 3	D	C	CLOSET			install smoke detector <i>large Storage Closet</i>				
* 15 a5 a1	B	C	CLOSET			post no combustibile storage sign <i>Mechanical Rm Door</i>				
* 00 00 99	F	C	KITCHEN			Mount Fire Extinguisher <i>kitchen</i>				
* 16 f1 07	B	C	KITCHEN			install gfci within 6 ft water supply <i>Near Ice Maker</i>				
* 16 f1 07	B	C	KITCHEN			install gfci within 6 ft water supply <i>Near Sink</i>				
* 11 a3 2	C	C	MECH RM			post mechanical room sign <i>Near Cafe Sink</i>				
* 16 e3 3	D	N	001			install fire alarm pull station <i>Both end of Corridor</i>				
* 16 e6 a	D	N	001			install strobe light <i>Both ends of Corridor</i>				
* 16 e3 3	D	N	002			install fire alarm pull station <i>Both Ends of Corridor</i>				
* 16 e6 a	D	N	002			install strobe light <i>One on each end by Stairways.</i>				
13 o7 02	B	N	00RR			install screens <i>All Student Restrooms</i>				
* 08 c 1	C	N	00RR			remove/replace key deadbolts <i>All Student R.R.</i>				
10 p1 20	B	N	0GRR			install hand blower <i>Repair Hand Blowers</i>				
* 12 a	F	N	104A			remove combustibile materials <i>Paneling in Closet Prev. S-104A</i>				
* 16 f1 02	B	N	105			install electric receptacle cover				
* 09 d 79	B	N	105			repair torn carpet <i>Trip hazard</i>				
* 09 b0 01	B	N	106			repair ceiling tiles				
* 09 b0 01	B	N	206			repair ceiling tiles				
* 16 e6 aa	F	S	001			Repair strobe/horn <i>South Corridor both ends Prev. N-1</i>				
* 16 e3 3	D	S	002			install fire alarm pull station <i>Each Stairwell Exit Prev. N-2</i>				
* 08 c 1	C	S	002			remove/replace key deadbolts <i>Upper Corridor Both Ends Prev. N-2</i>				
13 o7 02	B	S	00RR			install screens <i>All student restrooms</i>				
* 08 c 1	C	S	00RR			remove/replace key deadbolts <i>Student Restrooms _</i>				

**Comprehensive Safety Inspection
State Requirements for Educational Facilities**

Initial Inspection: Dec 14, 2009

Safety Department
4200A N.W. 10th Avenue
Oakland Park, FL 33309
(754) 321-4200

Fiscal Year: 2009-2010
Broward County School District - Charter Schools
Somerset Academy East Preparatory Loc. No: 5391
2000 South State Road 7
Miramar, FL 33027
(954) 987-7890

Miramar Fire Rescue
14801 SW 27th Street
Miramar, FL 33025
(954) 602-4602

69A-58 No.	Sub Para.	Pri	Location		Type Def. M-O-C	Est. Cost	Deficiency Description and Corrective Action Required	# of Times Cited	Scheduled for Correction Not Later Than	Current Year Status	Work Order #
			Bldg No.	Room No.							
*	08 a	01	B	S	00RR		repair door (wood) <i>Upper Girls R.R.</i>				
*	16 f1	02	B	S	101		install electric receptacle cover <i>under whiteboard</i>				
*	12 a		F	S	102		remove combustibile materials <i>Felt Covering table</i>				
*	16 f1	02	B	S	103		install electric receptacle cover				
	02 c8	1	B	S	9599		remove unsafe fence <i>Barbs on fence</i>				
*	13 a2	a6	B	S	CLOSET		remove improperly stored chemicals <i>Unlabeled spray Bride- East Closet</i>				
*	16 f1	09	B	S	STORAGE		remove extension cords <i>Upper Storage Closet E. End</i>				

The remainder of this page intentionally left blank.

**Comprehensive Safety Inspection
State Requirements for Educational Facilities**

Initial Inspection: Dec 14, 2009

Safety Department
4200A N.W. 10th Avenue
Oakland Park, FL 33309
(754) 321-4200


Fiscal Year: 2009-2010
Broward County School District - Charter Schools
Somerset Academy East Preparatory Loc. No: 5391
2000 South State Road 7
Miramar, FL 33027
(954) 987-7890

Miramar Fire Rescue
14801 SW 27th Street
Miramar, FL 33025
(954) 602-4602

69A-58 No. Sub Para.	Pri	Location		Type Def. M-O-C	Est. Cost	Deficiency Description and Corrective Action Required	# of Times Cited	Scheduled for Correction Not Later Than	Current Year Status	Work Order #
		Bldg No.	Room No.							
* 10 a6 1	B	0	000			Install Door Closure <i>All Doors- to resist Weather Conditions (wind)</i>				
* T L E	F	0	000			Install Fish Number <i>All rooms, Spaces, areas</i>				
* 16 e3 3	D	0	000			install fire alarm pull station <i>All Exits</i>				
* 16 a	C	0	000			install illuminated exit sign <i>All required Exits</i>				
* 10 a5 1	B	1	001			repair door closure <i>North Exit Door office Corridor</i>				
* 15 a4 21	B	1	00RR			install exhaust fan/vent to exterior <i>Office Restroom</i>				
* 08 b 2	E	1	00RR			install rated fire doors <i>Solid Core Door on Ofc. R.R. Closet</i>				
* 16 c 1	C	1	100			Repair battery lighting <i>Reception Area</i>				
* 12 a	F	1	R.R.			remove combustible materials <i>Closet in ofc R.R.</i>				
cs 01 01	A	1	8087			Remove unsafe/broken Equipment <i>Column Support Damaged on N Covered</i>				

Total Non-Fire Safety Deficiencies 5
 Total Fire Safety Deficiencies(*): 39 (Includes 0 Serious Life Safety Deficiencies**)
 Total Deficiencies Cited: 44

For N, PK, KG-12 and Florida School for the Deaf and Blind ONLY:
 Ten Fire Exit Drills during the School Year Yes No (NFPA 101)


 Signature of Facility Administrator Attesting to Fire Exit Drills
 and Review of Report Acknowledging Awareness of Discovered Deficiencies.

12/14/09
 Signature Date

Signature of the respective authority having jurisdiction's firesafety inspector signifies compliance with Section 1013.12(2)(c), F. S.
 Signature of the respective school district's firesafety inspector signifies compliance with Section 1013.12(1)(c), F.S.

Scheduled Re-inspection Date no later than: Apr 15, 2010